

Certificate of Conformity

By the product certificate number:

No. 2622/0478-G-E1-CER

Issued to:

License holder:

Victron Energy B.V.
De Paal 35, 1351JG, Almere, Netherlands.

Trademark:



Contract number:

802190

It is certified that the product:

Type of product: **Inverter/charger with UPS functionality**

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140- 100 230V	MultiPlus-II 48/15000/200- 100 230V
Rated characteristics:			
Rated Power	8.0 kVA / 6.4 kW	10.0 kVA / 8.0 kW	15.0 kVA / 12.0 kW
Rated Voltage		AC input: 187-250 V _{ac} DC input: 38-66 V _{dc} AC output: 220-240 V _{ac} DC output: 48 V _{dc}	
Rated Frequency		50 Hz	
Firmware version	2621502	2627502	2619502
Number of phases		Single Phase	
Isolation transformer		Yes	

Is in compliance with the test standard:

- **NRS 097-2-1:2017 Edition 2.1 of July 2020. Grid interconnection of embedded generation.**
Part 2: Small-scale embedded generation. Section 1: Utility interface.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-39 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate supersedes certificate no. 2622/0478-G-CER

This certificate is first issued on 29th of August 2023.
This certificate is valid until the 29th of August 2028.

Madrid, 29th of September 2023.

Daniel Arranz Muñiz,
Certification Manager.

